



TEST REPORT

Send To: 3M891*M
Sweetener Express, Inc. DBA Baxter
Natural Spring Water
P.O. Box 30004
Stockton CA 95213
Attn: Mr. Greg Smith

Customer: 3M890
Sweetener Express, Inc. DBA Baxter Natural Spring
Water
2431 E. Mariposa Road
Stockton CA 95205
Attn: Mr. Greg Smith

Plant: 3M891
Baxter Natural Spring Water
35277 Baxter Road
Baxter CA 95701
Attn: Mr. Greg Smith

Product: Spring Water Source – Bulk Facility Co - Mingle
Test Type: TO - Testing Only

Thank you for having your product tested by NSF.

The enclosed report details the result of the testing performed on your product. Your program representative will be contacting you in the near future if there are any remaining issues concerning the status of this product.

Please do not hesitate to contact us if you have any immediate questions pertaining to your product.

Reviewer:

Kneen, Kurt - Director, Chemistry Laboratory

Status: **Complete**

Program: 0195 - Beverages Program
CC: Program Rep Allena Najor
Region: 01 - Domestic
PA Project: 9072923

Annual

General Information

Standard: USFDA - USFDA CFR Title 21 Part 165.110 Bottled Water

Clients Name for Product: Spring Water Source
Date and Time Collected: 9/13/10 14:00 EDT
Fluoride Action Limit: 2.4
Sample Taken From: Sample Valve

Sample Id: S-0000776833
Description: Spring Water Source 9/13/10 14:00 EDT
Sampled Date: 09/13/2010
Received Date: 09/14/2010

Testing Parameter	Detection Limit	Result	FDA SOQ	CA SOQ	Units
Physical Quality					
Alkalinity as CaCO3	5	47			mg/LCaCO3
Color	5	ND	15	15	Color Unit
Specific Conductance	0.1	100			umhos/cm
Corrosivity	0	-1.64			
Hardness, Total	2	38			mg/LCaCO3
Odor, Threshold	1	ND	3	3	TON
Solids Total Dissolved	5	91	500	500	mg/L
Turbidity	0.1	ND	5	5	NTU
pH	0.01	7.45			
Temperature	0	20			deg. C
Bicarbonate	5	58			mg/L HCO3
Disinfection Residuals/Disinfection By-Products					
Bromate	5	ND	10	10	ug/L
Chloramine, Total	0.05	ND	4	4	mg/L
Dichloramine	0.05	ND			mg/L
Monochloramine	0.05	ND			mg/L
Nitrogen trichloride	0.05	ND			mg/L
Chlorine, Total Residual	0.05	ND	4	4	mg/L
Chlorite	10	ND	1000	1000	ug/L
Chlorine Dioxide	0.1	ND	0.8	0.8	mg/L
Bromochloroacetic Acid	1	ND			ug/L
Dibromoacetic Acid	1	ND			ug/L
Dichloroacetic Acid	1	ND			ug/L
Monobromoacetic Acid	1	ND			ug/L
Monochloroacetic Acid	2	ND			ug/L
Total Haloacetic Acid	1	ND	60	60	ug/L
Trichloroacetic Acid	1	ND			ug/L
Radiologicals					
P1 Gross Alpha	5	ND	15	15	pCi/L
P1 Gross Beta	5	ND	50	50	pCi/L
Radium 226 by SM705 (modified)	1	ND			pCi/L
Radium 228 by Ra-05	1	ND			pCi/L
Total Radium	1	ND	5	5	pCi/L
Radon	200	360			pCi/L
Uranium	0.001	ND	0.03	0.03	mg/L

Inorganic Chemicals

Sample Id: S-0000776833

Testing Parameter	Detection Limit	Result	FDA SOQ	CA SOQ	Units
Inorganic Chemicals					
Aluminum	0.01	ND	0.2	0.2	mg/L
Antimony	0.0005	ND	0.006	0.006	mg/L
Arsenic	0.002	ND	0.01	0.01	mg/L
* Asbestos in Water (Ref: EPA 600/4-83/043,100.1)					
Amphibole Fibers	0.2	ND			MFL
Chrysotile Fibers	0.2	ND			MFL
Single Fiber Detection Limit	0.2	ND			MFL
* Asbestos in Water (Ref: EPA 600/4-83/043,100.1)					
Amphibole Fibers	0.2	ND			MFL
Chrysotile Fibers	0.2	ND			MFL
Single Fiber Detection Limit	0.2	ND			MFL
Barium	0.001	0.024	2	2	mg/L
Beryllium	0.0005	ND	0.004	0.004	mg/L
Bromide	10	ND			ug/L
Cadmium	0.0002	ND	0.005	0.005	mg/L
Calcium	0.02	9.9			mg/L
Chloride	2	ND	250	250	mg/L
Chromium (includes Hexavalent Chromium)	0.001	ND	0.1	0.1	mg/L
Copper	0.001	ND	1	1	mg/L
Cyanide, Total	0.01	ND	0.2	0.2	mg/L
Fluoride	0.1	ND	2.4	2.4	mg/L
Iron	0.02	ND	0.3	0.3	mg/L
Lead	0.001	ND	0.005	0.005	mg/L
Magnesium	0.02	3.3			mg/L
Manganese	0.001	ND	0.05	0.05	mg/L
Mercury	0.0002	ND	0.002	0.002	mg/L
Nickel	0.001	ND	0.1	0.1	mg/L
Nitrogen, Nitrate	0.05	0.08	10	10	mg/L N
Nitrogen, Nitrite	0.025	ND	1	1	mg/L N
Total Nitrate + Nitrite-Nitrogen	0.02	0.08	10	10	mg/L
Potassium	0.5	2.2			mg/L
Selenium	0.002	ND	0.05	0.05	mg/L
Silver	0.001	ND	0.1	0.1	mg/L
Sodium	0.5	4.1			mg/L
Sulfur, Sulfate	0.5	ND	250	250	mg/L
Surfactants (MBAS)	0.2	ND			mg/L
Thallium	0.0002	ND	0.002	0.002	mg/L
Phenolics	0.001	ND	0.001	0.001	mg/L
Zinc	0.01	ND	5	5	mg/L
Organic Chemicals					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	20	ug/L
Endothall (Ref: EPA 548.1) - (ug/L)					
Endothall	9	ND	100	100	ug/L
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	700	ug/L
Perchlorate (Ref: EPA 314.0)					

Sample Id: S-0000776833

Testing Parameter	Detection Limit	Result	FDA SOQ	CA SOQ	Units
Organic Chemicals					
Perchlorate	1	ND			ug/L
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	10	ND	30	30	pg/L
Carbamate Pesticides (Ref: 531.2)					
3-Hydroxycarbofuran	1	ND			ug/L
Aldicarb	1	ND			ug/L
Aldicarb sulfone	1	ND			ug/L
Aldicarb sulfoxide	1	ND			ug/L
Carbaryl	1	ND			ug/L
Carbofuran	1	ND	40	40	ug/L
Methomyl	1	ND			ug/L
Oxamyl	1	ND	200	200	ug/L
Herbicides (Ref: EPA 515.3)					
2,4,5-TP	0.2	ND	50	50	ug/L
2,4-D	0.1	ND	70	70	ug/L
Bentazon	0.2	ND			ug/L
Dalapon	1	ND	200	200	ug/L
DCPA Acid Metabolites	0.2	ND			ug/L
Dicamba	0.1	ND			ug/L
Dinoseb	0.2	ND	7	7	ug/L
Pentachlorophenol	0.04	ND	1	1	ug/L
Picloram	0.1	ND	500	500	ug/L
Multicomponent Pesticides and PCBs (Ref: EPA 505)					
Chlordane	0.2	ND	2	2	ug/L
PCB 1016	0.3	ND	0.5	0.5	ug/L
PCB 1221	0.4	ND	0.5	0.5	ug/L
PCB 1232	0.4	ND	0.5	0.5	ug/L
PCB 1242	0.3	ND	0.5	0.5	ug/L
PCB 1248	0.2	ND	0.5	0.5	ug/L
PCB 1254	0.2	ND	0.5	0.5	ug/L
PCB 1260	0.3	ND	0.5	0.5	ug/L
Total PCBs	0.4	ND	0.5	0.5	ug/L
Toxaphene	1	ND	3	3	ug/L
Semivolatile Organic Compounds (Ref: EPA 525.2)					
2,4-Dinitrotoluene	0.5	ND			ug/L
2,6-Dinitrotoluene	0.5	ND			ug/L
Alachlor	0.1	ND	2	2	ug/L
Aldrin	0.1	ND			ug/L
Atrazine	0.2	ND	3	3	ug/L
Benzo(a)Pyrene	0.1	ND	0.2	0.2	ug/L
bis(2-Ethylhexyl)adipate	2	ND	400	400	ug/L
bis(2-Ethylhexyl)phthalate (DEHP)	2	ND			ug/L
Butachlor	0.2	ND			ug/L
Butylbenzylphthalate	2	ND			ug/L
Di-n-butylphthalate	2	ND			ug/L
Dieldrin	0.5	ND			ug/L
Diethylphthalate	2	ND			ug/L

Sample Id: S-0000776833

Testing Parameter	Detection Limit	Result	FDA SOQ	CA SOQ	Units
Organic Chemicals					
Dimethylphthalate	2	ND			ug/L
Endrin	0.1	ND	2	2	ug/L
EPTC	0.5	ND			ug/L
Heptachlor	0.1	ND	0.4	0.4	ug/L
Heptachlor Epoxide	0.1	ND	0.2	0.2	ug/L
Hexachlorobenzene	0.1	ND	1	1	ug/L
Hexachlorocyclopentadiene	0.1	ND	50	50	ug/L
Lindane	0.1	ND	0.2	0.2	ug/L
Methoxychlor	0.1	ND	40	40	ug/L
Metolachlor	0.1	ND			ug/L
Metribuzin	0.1	ND			ug/L
Molinate	0.1	ND			ug/L
p,p'-DDE (4,4'-DDE)	0.5	ND			ug/L
Propachlor	0.1	ND			ug/L
Simazine	0.2	ND	4	4	ug/L
Terbacil	0.5	ND			ug/L
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	0.2	ug/L
Ethylene Dibromide (EDB)	0.01	ND	0.05	0.05	ug/L
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)					
1,1,1,2-Tetrachloroethane	0.5	ND			ug/L
1,1,1-Trichloroethane	0.5	ND	200	200	ug/L
1,1,2,2-Tetrachloroethane	0.5	ND			ug/L
1,1,2-Trichloroethane	0.5	ND	5	5	ug/L
1,1-Dichloroethane	0.5	ND			ug/L
1,1-Dichloroethylene	0.5	ND	7	7	ug/L
1,1-Dichloropropene	0.5	ND			ug/L
1,2,3-Trichlorobenzene	0.5	ND			ug/L
1,2,3-Trichloropropane	0.5	ND			ug/L
1,2,3-Trimethylbenzene	0.5	ND			ug/L
1,2,4-Trichlorobenzene	0.5	ND	70	70	ug/L
1,2,4-Trimethylbenzene	0.5	ND			ug/L
1,2-Dichlorobenzene	0.5	ND	600	600	ug/L
1,2-Dichloroethane	0.5	ND	5	5	ug/L
1,2-Dichloropropane	0.5	ND	5	5	ug/L
1,3,5-Trimethylbenzene	0.5	ND			ug/L
1,3-Dichlorobenzene	0.5	ND			ug/L
1,3-Dichloropropane	0.5	ND			ug/L
1,4-Dichlorobenzene	0.5	ND	75	75	ug/L
2,2-Dichloropropane	0.5	ND			ug/L
2-Chlorotoluene	0.5	ND			ug/L
4-Chlorotoluene	0.5	ND			ug/L
Benzene	0.5	ND	5	5	ug/L
Bromobenzene	0.5	ND			ug/L
Bromochloromethane	0.5	ND			ug/L
Bromodichloromethane	0.5	ND			ug/L

Sample Id: S-0000776833

Testing Parameter	Detection Limit	Result	FDA SOQ	CA SOQ	Units
Organic Chemicals					
Bromoform	0.5	ND			ug/L
Bromomethane	0.5	ND			ug/L
Carbon Tetrachloride	0.5	ND	5	5	ug/L
Chlorobenzene	0.5	ND	100	100	ug/L
Chlorodibromomethane	0.5	ND			ug/L
Chloroethane	0.5	ND			ug/L
Chloroform	0.5	ND			ug/L
Chloromethane	0.5	ND			ug/L
cis-1,2-Dichloroethylene	0.5	ND	70	70	ug/L
cis-1,3-Dichloropropene	0.5	ND			ug/L
Dibromomethane	0.5	ND			ug/L
Dichlorodifluoromethane	0.5	ND			ug/L
Ethyl Benzene	0.5	ND	700	700	ug/L
Hexachlorobutadiene	0.5	ND			ug/L
Isopropylbenzene (Cumene)	0.5	ND			ug/L
m-p-Xylenes	1	ND			ug/L
Methyl-tert-Butyl Ether (MTBE)	0.5	ND			ug/L
Methylene Chloride	0.5	ND	5	5	ug/L
n-Butylbenzene	0.5	ND			ug/L
n-Propylbenzene	0.5	ND			ug/L
Naphthalene	0.5	ND			ug/L
o-Xylene	0.5	ND			ug/L
p-Isopropyltoluene (Cymene)	0.5	ND			ug/L
sec-Butylbenzene	0.5	ND			ug/L
Styrene	0.5	ND	100	100	ug/L
tert-Butylbenzene	0.5	ND			ug/L
Tetrachloroethylene	0.5	ND	5	5	ug/L
Toluene	0.5	ND	1000	1000	ug/L
Total Trihalomethanes	0.5	ND	80	10	ug/L
Total Xylenes	0.5	ND			ug/L
trans-1,2-Dichloroethylene	0.5	ND	100	100	ug/L
trans-1,3-Dichloropropene	0.5	ND			ug/L
Trichloroethylene	0.5	ND	5	5	ug/L
Trichlorofluoromethane	0.5	ND			ug/L
Trichlorotrifluoroethane	0.5	ND			ug/L
Vinyl Chloride	0.5	ND	2	2	ug/L
Miscellaneous					
Total Coliform	1	<1	1	1	CFU/100mL

<<Additional Information>>

Sample Id: S-0000776833

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Physical Quality			
Alkalinity (Ref: SM 2320-B)	14-SEP-2010		
* Color (Ref: SM 2120-B)	14-SEP-2010	10:55	
Specific Conductance (Ref: EPA 120.1)	14-SEP-2010		
* Corrosivity (Ref: SM 2330-B)			
* Hardness, Total (Ref: EPA 200.7)			
* Odor, Threshold Number (Ref: EPA 140.1)	14-SEP-2010		
Solids, Total Dissolved (Ref: SM 2540-C)	15-SEP-2010		
Turbidity (Ref: EPA 180.1)	14-SEP-2010	11:15	
pH (Ref: SM4500-HB)	14-SEP-2010	13:18	
* Bicarbonate (Ref: SM 2320-B)			
Disinfection Residuals/Disinfection By-Products			
Bromate (Ref: EPA 300.1)	15-SEP-2010		
* Chloramines (Ref: SM 4500-CI-G)	14-SEP-2010	15:05	
* Chlorine, Total Residual (ref. Hach 8167)	14-SEP-2010	13:10	
Chlorite (Ref: EPA 300.1)	15-SEP-2010		
* Chlorine Dioxide (Ref: SM 4500-CIO2-D)	14-SEP-2010	15:05	
Haloacetic Acids (Ref: EPA 552.2)	21-SEP-2010		20-SEP-2010
Radiologicals			
(1) * Gross Alpha/Beta Counts (Ref: EPA 900)- General Engineering	27-SEP-2010		
(1) * Total Radium (General Engineering)	27-SEP-2010		
(1) * Radon in Drinking Water, EPA 600/2-87/082, AppB (General Engineering Laboratories, Inc.)	17-SEP-2010		
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Inorganic Chemicals			
Aluminum (Ref: EPA 200.8)	23-SEP-2010		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
(2) * Asbestos in Water (Ref: EPA 600/4-83/043,100.1)	16-SEP-2010	1253	
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Bromide (Ref: EPA 300.1)	15-SEP-2010		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	23-SEP-2010		
Chloride (Ref: EPA 300.0)	14-SEP-2010		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		

Sample Id: S-0000776833

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Inorganic Chemicals			
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Cyanide, Total (Ref: EPA 335.4)	17-SEP-2010		
Fluoride (Ref: SM 4500-F-C)	14-SEP-2010		
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	23-SEP-2010		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	23-SEP-2010		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Nitrogen, Nitrate (Ref: EPA 300.0)	14-SEP-2010	1232	
Nitrogen, Nitrite (Ref: EPA 300.0)	14-SEP-2010	1232	
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	23-SEP-2010		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	23-SEP-2010		
Sulfur, Sulfate (Ref: EPA 300.0)	14-SEP-2010		
* Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	14-SEP-2010	14:03	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
* Phenolics, Total Recoverable (Ref: EPA 420.2)	20-SEP-2010		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	23-SEP-2010		
Organic Chemicals			
Diquat (Ref: EPA 549.2)	16-SEP-2010		14-SEP-2010
Endothall (Ref: EPA 548.1) - (ug/L)	17-SEP-2010		16-SEP-2010
Glyphosate (Ref: EPA 547)	23-SEP-2010		
Perchlorate (Ref: EPA 314.0)	27-SEP-2010		
2,3,7,8-TCDD (Ref: EPA 1613B)	23-SEP-2010		22-SEP-2010
Carbamate Pesticides (Ref: 531.2)	17-SEP-2010		
Herbicides (Ref: EPA 515.3)	25-SEP-2010		21-SEP-2010
Multicomponent Pesticides and PCBs (Ref: EPA 505)	22-SEP-2010		
Semivolatile Organic Compounds (Ref: EPA 525.2)	23-SEP-2010		23-SEP-2010
Volatiles: EDB and DBCP (Ref: EPA 504.1)	22-SEP-2010		
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	15-SEP-2010		
Miscellaneous			
Total Coliform by SM 9222B	15-SEP-2010	16:10	14-SEP-2010 16:10

Sample Id: S-0000776833

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Miscellaneous			
* Volatiles: Regulated and Monitoring VOC's (Ref: EPA 502.2) - (Analytical Laboratory Services)			
* Haloacetic Acids (Ref: EPA 552.2 - (Analytical Laboratory Services)			

Job Notes:

This report replaces the previously issued report #F120101007094547.
The report is being re-issued to correct the Product description.
This does not change the overall status of the report.

Testing Laboratories:

Flag	Id	Address
All work performed at: (Unless otherwise specified)	NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105
(1)	GENENG	GEL Laboratories LLC 2040 Savage Road Charleston, SC 29407 NELAP PA certificate number 68-000485 Arizona License #AZ0668
(2)	BVNA	Bureau Veritas North America 22345 Roethel Dr. Novi, MI 48375 Arizona License #AZ0675

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C0185	* Total Radium (General Engineering)
C1010	* Odor, Threshold Number (Ref: EPA 140.1)
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C3012	* Asbestos in Water (Ref: EPA 600/4-83/043,100.1)
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3015	Bromate (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfur, Sulfate (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: EPA 335.4)
C3021	* Phenolics, Total Recoverable (Ref: EPA 420.2)
C3025	Chlorite (Ref: EPA 300.1)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	* Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	* Color (Ref: SM 2120-B)
C3158	Specific Conductance (Ref: EPA 120.1)
C3159	pH (Ref: SM4500-HB)
C3161	* Hardness, Total (Ref: EPA 200.7)
C3166	* Bicarbonate (Ref: SM 2320-B)
C3167	* Chlorine, Total Residual (ref. Hach 8167)



A-00041440

This report shall not be reproduced, except in its entirety, without the written approval of NSF. This report does not represent NSF Certification or authorization to use the NSF Mark. Authorization to use the NSF Mark is limited to products appearing in the Company's Official NSF Listing, (www.nsf.org). The results relate only to those items tested.

References to Testing Procedures: (Cont'd)

NSF Reference	Parameter / Test Description
C3168	* Chlorine Dioxide (Ref: SM 4500-ClO2-D)
C3169	* Chloramines (Ref: SM 4500-Cl-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	Alkalinity (Ref: SM 2320-B)
C3188	Silver in Drinking Water by ICPMS (Ref: EPA 200.8)
C3198	* Radon in Drinking Water, EPA 600/2-87/082, AppB (General Engineering Laboratories, Inc.)
C3210	* Corrosivity (Ref: SM 2330-B)
C3244	* Gross Alpha/Beta Counts (Ref: EPA 900)- General Engineering
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C4076	Carbamate Pesticides (Ref: 531.2)
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref: EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4198	Haloacetic Acids (Ref: EPA 552.2) (comment: NELAC approved method)
C4202	Herbicides (Ref: EPA 515.3)
C4292	Multicomponent Pesticides and PCBs (Ref: EPA 505)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4497	Perchlorate (Ref: EPA 314.0)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)
M0011	Total Coliform by SM 9222B

Certifications:

Arizona (# AZ0655)	California (# 01149 CA)	Connecticut (# PH-0625)
Florida (# E-87752 FL)	Hawaii	Indiana
Maryland (# 201)	Michigan (# 0048)	North Carolina (# 26701)
New Jersey (# 62770)	Nevada (# MI000302010A)	New York (# 11206)
Pennsylvania (# 68-00312)	South Carolina (# 81005)	Virginia (# 00045)
Vermont (# VT 11206)		

Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.

The reported result for Odor, Phenolics, Potassium, Specific Conductance and Total Residual Chlorine cannot be used for compliance purposes within the State of Arizona.

Notes:

- 1) Mineral water is exempt from the 500 mg/L TDS allowable level.
 - 2) Fluoride SOQ is dependent on the annual average of maximum daily air temperature at the location where the bottled water is sold at retail.
- See 21 CFR 165.110(b)(4)(ii)



A-00041440

This report shall not be reproduced, except in its entirety, without the written approval of NSF. This report does not represent NSF Certification or authorization to use the NSF Mark. Authorization to use the NSF Mark is limited to products appearing in the Company's Official NSF Listing. (www.nsf.org). The results relate only to those items tested.