



Send To: 00010

Mr. Joe Sokolowski
3 Springs Water Company
1800 Pine Run Road
Laurel Run, PA 18702

Facility: 00011

3 Springs Water Company
1800 Pine Run Road
Laurel Run PA 18702
United States

Result COMPLETE

Report Date 27-MAR-2017

Customer Name 3 Springs Water Company
Tested To USFDA CFR Title 21 Part 165.110
Description 3 Springs Source Water
Test Type Source Water
Job Number A-00245244
Project Number 10042708 (CLAB)
Project Manager Anna Ciechanowski

Thank you for having your product tested by NSF International.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization *Kerri Levanseler*
Kerri Levanseler - Director, Chemistry Laboratory

Date 26-MAR-2017



General Information

Standard: USFDA CFR Title 21 Part 165.110
Date and Time Sampled: 02/14/2017 16:20 EST
Product Description: 3 Springs Source Water

Sample Id: **S-0001339318**
Description: 3 Springs Source Water - 02/14/2017 16:20 EST
Sampled Date: 02/14/2017
Received Date: 02/15/2017

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Physical Quality					
Alkalinity as CaCO3	5	ND		mg/LCaCO3	
Color	5	ND	15	Color Unit	Pass
Specific Conductance	10	24		umhos/cm	
Corrosivity	0	-5.28			
Hardness, Total	2	8		mg/LCaCO3	
Solids Total Dissolved	5	16	500	mg/L	Pass
Turbidity	0.1	ND	5	NTU	Pass
pH	0.01	5.81			
Temperature	0	20		deg. C	
Bicarbonate	5	ND		mg/L HCO3	
Odor, Threshold	1	ND	3	TON	Pass
Disinfection Residuals/Disinfection By-Products					
Chloramine, Total	0.05	ND	4	mg/L	Pass
Dichloramine	0.05	ND		mg/L	
Monochloramine	0.05	ND		mg/L	
Nitrogen trichloride	0.05	ND		mg/L	
Chlorine Dioxide	0.1	ND	0.8	mg/L	Pass
Chlorine, Total Residual	0.05	ND	4	mg/L	Pass
Radiologicals					
Radium-226	1	ND		pCi/L	
Radium-226, Radium-228 Combined	1	ND	5	pCi/L	Pass
Radium-228	1	ND		pCi/L	
Uranium	0.001	ND	0.03	mg/L	Pass
P1 Gross Alpha	3	ND	15	pCi/L	Pass
P1 Gross Beta	4	ND	50	pCi/L	Pass
Inorganic Chemicals					
Aluminum	0.01	0.01	0.2	mg/L	Pass
Antimony	0.0005	ND	0.006	mg/L	Pass
Arsenic	0.002	ND	0.01	mg/L	Pass
* Asbestos in Water (Ref: EPA 600/4-83/043,100.1)-Bureau Veritas					
Amphibole Fibers	0.2	ND		MFL	
Chrysotile Fibers	0.2	ND		MFL	
Single Fiber Detection Limit	0.2	ND		MFL	
Barium	0.001	0.008	2	mg/L	Pass
Beryllium	0.0005	ND	0.004	mg/L	Pass
Cadmium	0.0002	ND	0.005	mg/L	Pass
Calcium	0.02	1.4		mg/L	
Chromium (includes Hexavalent Chromium)	0.001	ND	0.1	mg/L	Pass
Copper	0.001	0.002	1	mg/L	Pass
Cyanide, Total	0.005	ND	0.2	mg/L	Pass
Fluoride	0.1	ND	2.4	mg/L	Pass



Sample Id: **S-0001339318**

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Inorganic Chemicals					
Iron	0.02	ND	0.3	mg/L	Pass
Lead	0.0005	ND	0.005	mg/L	Pass
Magnesium	0.02	0.98		mg/L	
Manganese	0.001	0.009	0.05	mg/L	Pass
Mercury	0.0002	ND	0.002	mg/L	Pass
Nickel	0.001	0.002	0.1	mg/L	Pass
Total Nitrate + Nitrite-Nitrogen	0.02	ND	10	mg/L	Pass
Potassium	0.5	ND		mg/L	
Selenium	0.002	ND	0.05	mg/L	Pass
Silver	0.001	ND	0.1	mg/L	Pass
Sodium	0.5	0.6		mg/L	
Surfactants (MBAS)	0.2	ND		mg/L	
Thallium	0.0002	ND	0.002	mg/L	Pass
Zinc	0.01	ND	5	mg/L	Pass
Organic Chemicals					
Perchlorate (Ref: EPA 314.0)					
Perchlorate	1	ND		ug/L	
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	10	ND	30	pg/L	Pass

Sample Id: **S-0001339559**

Description: 3 Springs Source Water - 3/1/2017 14:30 EST

Sampled Date: 03/01/2017

Received Date: 03/02/2017

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Disinfection Residuals/Disinfection By-Products					
Bromate	5	ND	10	ug/L	Pass
Chlorite	10	ND	1000	ug/L	Pass
Bromochloroacetic Acid	1	ND		ug/L	
Dibromoacetic Acid	1	ND		ug/L	
Dichloroacetic Acid	1	ND		ug/L	
Monobromoacetic Acid	1	ND		ug/L	
Monochloroacetic Acid	2	ND		ug/L	
Total Haloacetic Acid	1	ND	60	ug/L	Pass
Trichloroacetic Acid	1	ND		ug/L	
Radiologicals					
Radon	200	ND		pCi/L	
Inorganic Chemicals					
Bromide	10	ND		ug/L	
Chloride	2	ND	250	mg/L	Pass
Nitrogen, Nitrate	0.05	ND	10	mg/L N	Pass
Nitrogen, Nitrite	0.025	ND	1	mg/L N	Pass
Sulfate as SO4	0.5	5.1	250	mg/L	Pass
Phenolics	0.001	ND	0.001	mg/L	Pass
Organic Chemicals					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	ug/L	Pass



Sample Id: S-0001339559

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
Endothall (Ref. EPA 548.1) - (ug/L)					
Endothall	9	ND	100	ug/L	Pass
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	ug/L	Pass
Carbamate Pesticides (Ref: 531.2)					
3-Hydroxycarbofuran	1	ND		ug/L	
Aldicarb	1	ND		ug/L	
Aldicarb sulfone	1	ND		ug/L	
Aldicarb sulfoxide	1	ND		ug/L	
Carbaryl	1	ND		ug/L	
Carbofuran	1	ND	40	ug/L	Pass
Methomyl	1	ND		ug/L	
Oxamyl	1	ND	200	ug/L	Pass
Herbicides (Ref: EPA 515.3)					
2,4,5-TP	0.2	ND	50	ug/L	Pass
2,4-D	0.1	ND	70	ug/L	Pass
Bentazon	0.2	ND		ug/L	
Dalapon	1	ND	200	ug/L	Pass
DCPA Acid Metabolites	0.2	ND		ug/L	
Dicamba	0.1	ND		ug/L	
Dinoseb	0.2	ND	7	ug/L	Pass
Pentachlorophenol	0.04	ND	1	ug/L	Pass
Picloram	0.1	ND	500	ug/L	Pass
Semivolatile Organic Compounds (Ref: EPA 525.2)					
2,4 Dinitrotoluene	0.5	ND		ug/L	
2,6-Dinitrotoluene	0.5	ND		ug/L	
Alachlor	0.1	ND	2	ug/L	Pass
Aldrin	0.1	ND		ug/L	
Atrazine	0.2	ND	3	ug/L	Pass
Benzo(a)Pyrene	0.1	ND	0.2	ug/L	Pass
bis(2-Ethylhexyl)adipate	2	ND	400	ug/L	Pass
bis(2-Ethylhexyl)phthalate (DEHP)	2	ND	6	ug/L	Pass
Butachlor	0.2	ND		ug/L	
Butylbenzylphthalate	2	ND		ug/L	
Di-n-butylphthalate	2	ND		ug/L	
Dieldrin	0.5	ND		ug/L	
Diethylphthalate	2	ND		ug/L	
Dimethylphthalate	2	ND		ug/L	
Endrin	0.1	ND	2	ug/L	Pass
EPTC	0.5	ND		ug/L	
Heptachlor	0.1	ND	0.4	ug/L	Pass
Heptachlor Epoxide	0.1	ND	0.2	ug/L	Pass
Hexachlorobenzene	0.1	ND	1	ug/L	Pass
Hexachlorocyclopentadiene	0.1	ND	50	ug/L	Pass
Lindane	0.1	ND	0.2	ug/L	Pass
Methoxychlor	0.1	ND	40	ug/L	Pass
Metolachlor	0.1	ND		ug/L	
Metribuzin	0.1	ND		ug/L	
Molinate	0.1	ND		ug/L	



Sample Id: S-0001339559

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
p,p'-DDE (4,4'-DDE)	0.5	ND		ug/L	
Propachlor	0.1	ND		ug/L	
Simazine	0.2	ND	4	ug/L	Pass
Terbacil	0.5	ND		ug/L	
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	ug/L	Pass
Ethylene Dibromide (EDB)	0.01	ND	0.05	ug/L	Pass
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)					
1,1,1,2-Tetrachloroethane	0.5	ND		ug/L	
1,1,1-Trichloroethane	0.5	ND	200	ug/L	Pass
1,1,2,2-Tetrachloroethane	0.5	ND		ug/L	
1,1,2-Trichloroethane	0.5	ND	5	ug/L	Pass
1,1-Dichloroethane	0.5	ND		ug/L	
1,1-Dichloroethylene	0.5	ND	7	ug/L	Pass
1,1-Dichloropropene	0.5	ND		ug/L	
1,2,3-Trichlorobenzene	0.5	ND		ug/L	
1,2,3-Trichloropropane	0.5	ND		ug/L	
1,2,3-Trimethylbenzene	0.5	ND		ug/L	
1,2,4-Trichlorobenzene	0.5	ND	70	ug/L	Pass
1,2,4-Trimethylbenzene	0.5	ND		ug/L	
1,2-Dichlorobenzene	0.5	ND	600	ug/L	Pass
1,2-Dichloroethane	0.5	ND	5	ug/L	Pass
1,2-Dichloropropane	0.5	ND	5	ug/L	Pass
1,3,5-Trimethylbenzene	0.5	ND		ug/L	
1,3-Dichlorobenzene	0.5	ND		ug/L	
1,3-Dichloropropane	0.5	ND		ug/L	
1,4-Dichlorobenzene	0.5	ND	75	ug/L	Pass
2,2-Dichloropropane	0.5	ND		ug/L	
2-Chlorotoluene	0.5	ND		ug/L	
4-Chlorotoluene	0.5	ND		ug/L	
Benzene	0.5	ND	5	ug/L	Pass
Bromobenzene	0.5	ND		ug/L	
Bromochloromethane	0.5	ND		ug/L	
Bromodichloromethane	0.5	ND		ug/L	
Bromoform	0.5	ND		ug/L	
Bromomethane	0.5	ND		ug/L	
Carbon Tetrachloride	0.5	ND	5	ug/L	Pass
Chlorobenzene	0.5	ND	100	ug/L	Pass
Chlorodibromomethane	0.5	ND		ug/L	
Chloroethane	0.5	ND		ug/L	
Chloroform	0.5	ND		ug/L	
Chloromethane	0.5	ND		ug/L	
cis-1,2-Dichloroethylene	0.5	ND	70	ug/L	Pass
cis-1,3-Dichloropropene	0.5	ND		ug/L	
Dibromomethane	0.5	ND		ug/L	
Dichlorodifluoromethane	0.5	ND		ug/L	
Ethyl Benzene	0.5	ND	700	ug/L	Pass
Hexachlorobutadiene	0.5	ND		ug/L	
Isopropylbenzene (Cumene)	0.5	ND		ug/L	



Sample Id: S-0001339559

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
m+p-Xylenes	1	ND		ug/L	
Methyl Ethyl Ketone	5	ND		ug/L	
Methyl-tert-Butyl Ether (MTBE)	0.5	ND		ug/L	
Methylene Chloride	0.5	ND	5	ug/L	Pass
n-Butylbenzene	0.5	ND		ug/L	
n-Propylbenzene	0.5	ND		ug/L	
Naphthalene	0.5	ND		ug/L	
o-Xylene	0.5	ND		ug/L	
p-Isopropyltoluene (Cymene)	0.5	ND		ug/L	
sec-Butylbenzene	0.5	ND		ug/L	
Styrene	0.5	ND	100	ug/L	Pass
tert-Butylbenzene	0.5	ND		ug/L	
Tetrachloroethylene	0.5	ND	5	ug/L	Pass
Toluene	0.5	ND	1000	ug/L	Pass
Total Trihalomethanes	0.5	ND	80	ug/L	Pass
Total Xylenes	0.5	ND	10000	ug/L	Pass
trans-1,2-Dichloroethylene	0.5	ND	100	ug/L	Pass
trans-1,3-Dichloropropene	0.5	ND		ug/L	
Trichloroethylene	0.5	ND	5	ug/L	Pass
Trichlorofluoromethane	0.5	ND		ug/L	
Trichlorotrifluoroethane	0.5	ND		ug/L	
Vinyl Chloride	0.5	ND	2	ug/L	Pass
Chlorinated Pesticides and Organohalides by EPA 508.1					
Chlordane	0.1	ND	2	ug/L	Pass
Endrin	0.01	ND	2	ug/L	Pass
PCB 1016	0.1	ND	0.5	ug/L	Pass
PCB 1221	0.1	ND	0.5	ug/L	Pass
PCB 1232	0.1	ND	0.5	ug/L	Pass
PCB 1242	0.1	ND	0.5	ug/L	Pass
PCB 1248	0.1	ND	0.5	ug/L	Pass
PCB 1254	0.1	ND	0.5	ug/L	Pass
PCB 1260	0.1	ND	0.5	ug/L	Pass
Total PCBs	0.1	ND	0.5	ug/L	Pass
Toxaphene	0.1	ND	3	ug/L	Pass



<<Additional Information>>

Sample Id: S-0001339318

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Physical Quality			
Alkalinity (Ref: SM 2320-B)	17-FEB-2017		
Color (Ref: SM 2120-B)	15-FEB-2017	14:35	
Specific Conductance (Ref: EPA 120.1)	17-FEB-2017		
Corrosivity (Ref: SM 2330-B)			
Hardness, Total (Ref: EPA 200.7)			
Solids, Total Dissolved (Ref: SM 2540-C)	16-FEB-2017		
Turbidity (Ref: EPA 180.1)	15-FEB-2017	13:50:00	
pH (Ref: SM4500-HB)	15-FEB-2017	15:15:48	
Bicarbonate (Ref: SM 2320-B)			
Odor, Threshold Number (Ref. Standard Methods 2150 B)	16-FEB-2017		
Disinfection Residuals/Disinfection By-Products			
Chloramines (Ref: SM 4500-Cl-G)	15-FEB-2017	13:16:00	
Chlorine Dioxide (Ref: SM 4500-ClO2-D)	15-FEB-2017	13:16:00	
Chlorine, Total Residual (ref. SM 4500CL-G)	15-FEB-2017	13:16:00	
Radiologicals			
Total Radium-226, Radium-228 Combined Activity (SM7500Ra-B & SM7500Ra-D)	23-FEB-2017		
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)	23-FEB-2017		
Inorganic Chemicals			
Aluminum (Ref: EPA 200.8)	21-FEB-2017		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
# * Asbestos in Water (Ref: EPA 600/4-83/043,100.1)-Bureau Veritas	23-FEB-2017	14:26	
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	21-FEB-2017		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Cyanide, Total (Ref: EPA 335.4)	1-MAR-2017		
Fluoride (Ref: SM 4500-F-C)	22-FEB-2017		
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	21-FEB-2017		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		



<<Additional Information>>

Sample Id: S-0001339318

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Inorganic Chemicals			
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	21-FEB-2017		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	21-FEB-2017		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8)	17-FEB-2017		
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	21-FEB-2017		
Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	15-FEB-2017	16:08:00	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	21-FEB-2017		
Organic Chemicals			
Perchlorate (Ref: EPA 314.0)	17-FEB-2017		
2,3,7,8-TCDD (Ref: EPA 1613B)	23-FEB-2017		21-FEB-2017



<<Additional Information>>

Sample Id: S-0001339559

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Disinfection Residuals/Disinfection By-Products			
Bromate (Ref: EPA 300.1)	9-MAR-2017		
Chlorite (Ref: EPA 300.1)	9-MAR-2017		
Halobacetic Acids (Ref: EPA 552.2)	9-MAR-2017		8-MAR-2017
Radiologicals			
# * Radon in Drinking Water, EPA 600/2-87/082, AppB (General Engineering Laboratories, Inc.)	3-MAR-2017		
Inorganic Chemicals			
Bromide (Ref: EPA 300.1)	9-MAR-2017		
Chloride (Ref: EPA 300.0)	3-MAR-2017		
Nitrogen, Nitrate (Ref: EPA 300.0)	3-MAR-2017	17:15:00	
Nitrogen, Nitrite (Ref: EPA 300.0)	3-MAR-2017	00:58:00	
Sulfate as SO4 (Ref: EPA 300.0)	3-MAR-2017		
* Phenolics, Total Recoverable (Based on EPA 420.2)	15-MAR-2017		
Organic Chemicals			
Diquat (Ref: EPA 549.2)	7-MAR-2017		7-MAR-2017
Endothall (Ref: EPA 548.1) - (ug/L)	8-MAR-2017		6-MAR-2017
Glyphosate (Ref: EPA 547)	6-MAR-2017		
Carbamate Pesticides (Ref: 531.2)	8-MAR-2017		
Herbicides (Ref: EPA 515.3)	15-MAR-2017		13-MAR-2017
Semivolatile Organic Compounds (Ref: EPA 525.2)	7-MAR-2017		6-MAR-2017
Volatiles: EDB and DBCP (Ref: EPA 504.1)	4-MAR-2017		
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	3-MAR-2017		
Chlorinated Pesticides and Organohalides by EPA 508.1	14-MAR-2017		



Testing Laboratories:

Flag	Id	Address
All work performed at: (Unless otherwise specified)	NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105
#	BVNA	Bureau Veritas North America 3380 Chastain Meadows Pkwy 300 Kennesaw, GA 30144 Arizona License #AZ0675
#	GENENG	GEL Laboratories LLC 2040 Savage Road Charleston, SC 29407 NELAP PA certificate number 68-000485 Arizona License #AZ0668

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C0842	Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)
C0980	Total Radium-226, Radium-228 Combined Activity (SM7500Ra-B & SM7500Ra-D)
C1188	Odor, Threshold Number (Ref. Standard Methods 2150 B)
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C3012	* Asbestos in Water (Ref: EPA 600/4-83/043,100.1)-Bureau Veritas
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3015	Bromate (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfate as SO4 (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: EPA 335.4)
C3021	* Phenolics, Total Recoverable (Based on EPA 420.2)
C3025	Chlorite (Ref: EPA 300.1)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	Color (Ref: SM 2120-B)



References to Testing Procedures: (Cont'd)

NSF Reference	Parameter / Test Description
C3158	Specific Conductance (Ref: EPA 120.1)
C3159	pH (Ref: SM4500-HB)
C3161	Hardness, Total (Ref: EPA 200.7)
C3166	Bicarbonate (Ref: SM 2320-B)
C3168	Chlorine Dioxide (Ref: SM 4500-CIO2-D)
C3169	Chloramines (Ref: SM 4500-Cl-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	Alkalinity (Ref: SM 2320-B)
C3188	Silver in Drinking Water by ICPMS (Ref: EPA 200.8)
C3198	* Radon in Drinking Water, EPA 600/2-87/082, AppB (General Engineering Laboratories, Inc.)
C3210	Corrosivity (Ref: SM 2330-B)
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C3393	Chlorine, Total Residual (ref. SM 4500CL-G)
C4076	Carbamate Pesticides (Ref: 531.2)
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref. EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4198	Haloacetic Acids (Ref: EPA 552.2)
C4202	Herbicides (Ref: EPA 515.3)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4497	Perchlorate (Ref: EPA 314.0)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)
C4669	Chlorinated Pesticides and Organohalides by EPA 508.1

Certifications:

Arizona (# AZ0655)	California (# 03214 CA)	Connecticut (# PH-0625)
Florida (# E-87752 FL)	Hawaii	Indiana
Maryland (# 201)	Michigan (# 0048)	North Carolina (# 26701)
New Jersey (# MI770)	Nevada (# MI000302010A)	New York (# 11206)
Pennsylvania (# 68-00312)	South Carolina (# 81005)	Virginia (# 00045)
Vermont (# VT 11206)		

Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.

The reported result for Odor, Phenolics, Potassium, Specific Conductance, Radon and Total Residual Chlorine cannot be used for compliance purposes within the State of Arizona.

Notes:

- 1) Bottled water sold in the United States shall not contain Fluoride in excess of the levels published by the USFDA in 21 CFR Part 165.110. These levels are based on the annual average of maximum daily air temperatures at the location where the bottled water is sold at retail. Please refer to the most current edition of the regulation to determine the Fluoride maximum level that pertains to your product.
- 2) A blank on the FDA SOQ column indicates that no maximum level has been established by the FDA for that contaminant.
- 3) An ND result means that the contaminant was not detected at or above the reporting limit.

For a list of NSF International Method Detection Limits refer to



http://www.nsf.org/media/eneews/documents/minimum_detection_level_spreadsheet.pdf